

Montecito Community Microgrid Renewables-driven Resilience for Critical Facilities



Craig Lewis
Executive Director
Clean Coalition
650-796-2353 mobile
craig@clean-coalition.org

Clean Coalition (non-profit) Mission



To accelerate the transition to renewable energy and a modern grid through technical, policy, and project development expertise

Community Microgrids = the Grid of the Future



A Community Microgrid is a new approach for designing and operating the electric grid, stacked with local renewables and staged for resilience.


Key features:

- A targeted and coordinated local grid area served by one or more distribution substations
- High penetrations of local renewables and other Distributed Energy Resources (DER) such as energy storage and demand response
- <u>Staged capability</u> for ongoing renewables-driven power backup for critical and prioritized loads across the grid area
- A solution that can be readily extended throughout a utility service territory – and replicated into any utility service territory around the world




Community Microgrid key stakeholders






Solar Siting Survey (SSS) for Montecito






Montecito Community Microgrid map view





Hot Springs Feeder is the key to success





Montecito Community Microgrid block diagram







Diagram Elements



Autonomously Controllable Microgrid Relay/Switch (open, closed)

Montecito SSS summary






Montecito Community Microgrid has solar siting potential of 4.6 MW, over 40% of the total Montecito SSS findings; of which about 90% is on parking lots.

Solar Siting Survey	Summary by Sites							
	Count	kW_Total	PV W_AC >=	500 kW	> and >=	100 kW	Less than	100 kW
	Sites		Sites		Sites		Sites	
Totals:	33	11,251 kW	7	6,948 kW	14	3,606 kW	12	697 kW

Solar Siti	ing Survey	Aggregate F	acilities Su	mmary					
Aggregatio	Aggregation	Summary by Aggregation Type : PV at All Sites							
Aggregatio	оп туре	Count	kW_Total	PV W_AC >= "	500 kW	> and >=	100 kW	Less than	100 kW
Airport	☆ ~	-	-	-	-	-	-	-	-
Lodging		1	916	1	916	-	-	-	-
Biz	\$.	1	931	1	931	-	-	-	-
Edu		4	3,275	2	2,697	2	578	-	-
Shopping		2	2,224	2	2,224	-	-	-	-
Storage		-	-	-	-	-	-	-	-
Venue	☎ ─	1	370	-	-	1	370	-	-
		-	-	-	-	-	-	-	-
	Totals:	9	7,716 kW	6	6,768 kW	3	948 kW	-	- kW


Vons cluster






Coast Village strip






Four Seasons cluster





Sanitation District and Music Academy cluster






Athletic Club and Event Center cluster





Montecito Country Club





SSS for Montecito Country Club





Peek at the Community Microgrid future





Ecoplexus project at the Valencia Gardens Apartments in SF. ~800 kW meeting ~80% of the total annual load.


Backup Slides



Backup Slides


Montecito SSS Showing SCE Substations





Hot Springs Feeder via Santa Barbara Substation





Helena & Hot Springs Feeder details



Circuit Name	HOT SPRINGS
Voltage (kV)	16.00
Substation	SANTA BARBARA 66/16 kV
System	Goleta 220/66 System
Existing Generation (MW)	0.30
Queued Generation (MW)	0.00
Total Generation (MW)	0.30
Projected Load (MW)	10.74
Current Penetration Level (%)	2.75
Maximum Remaining Generation Capacity (MW)	12.90
15% Penetration Capacity (MW)	1.32
Deliverability Note	Interconnection studies in this area have identified adequate deliverability.

Circuit Name Voltage (kV) Substation	STANWOOD 16.00 SANTA BARBARA 66/16 kV
System	Goleta 220/66 System
Existing Generation (MW)	0.92
Queued Generation (MW)	0.00
Total Generation (MW) Projected Load (MW)	0.93 13.20
Current Penetration Level (%)	7.01
Maximum Remaining Generation Capacity (MW)	12.27
15% Penetration Capacity (MW)	1.05
Deliverability Note	Interconnection studies in this area have identified adequate deliverability.

Santa Barbara & Montecito Substation details



Substation	Santa Barbara 66/16 kV
System	Goleta 220/66 System
Existing Generation (MW)	3.78
Queued Generation (MW)	1.31
Total Generation (MW)	5.09
Projected Load (MW)	58.60
Current Penetration Level (%)	8.68
Maximum Remaining Generation Capacity (MW)	78.91
Deliverability Note	Interconnection studies in this area have identified adequate deliverability.

Substation Montecito 16/4.16 kV System Goleta 220/66 System Existing Generation (MW) 0.38 Queued Generation (MW) 0.06 Total Generation (MW) 0.44 Projected Load (MW) 4.80 Current Penetration Level (%) 9.14 Maximum Remaining Generation Capacity (MW) 5.57 Deliverability Note Interconnection studies in this area have identified adequate deliverability.		
Existing Generation (MW) Queued Generation (MW) Total Generation (MW) Projected Load (MW) Current Penetration Level (%) Maximum Remaining Generation Capacity (MW) Deliverability Note Interconnection studies in this area have identified adequate	Substation	Montecito 16/4.16 kV
Queued Generation (MW) Total Generation (MW) Projected Load (MW) Current Penetration Level (%) Maximum Remaining Generation Capacity (MW) Deliverability Note Interconnection studies in this area have identified adequate	System	Goleta 220/66 System
Total Generation (MW) Projected Load (MW) Current Penetration Level (%) Maximum Remaining Generation Capacity (MW) Deliverability Note Interconnection studies in this area have identified adequate	Existing Generation (MW)	0.38
Projected Load (MW) Current Penetration Level (%) Maximum Remaining Generation Capacity (MW) Deliverability Note Interconnection studies in this area have identified adequate	Queued Generation (MW)	0.06
Current Penetration Level (%) Maximum Remaining Generation Capacity (MW) 5.57 Deliverability Note Interconnection studies in this area have identified adequate	Total Generation (MW)	0.44
Maximum Remaining Generation Capacity (MW) 5.57 Deliverability Note Interconnection studies in this area have identified adequate	Projected Load (MW)	4.80
Deliverability Note Interconnection studies in this area have identified adequate	Current Penetration Level (%)	9.14
have identified adequate	Maximum Remaining Generation Capacity (MW)	5.57
	Deliverability Note	have identified adequate

SSS for Westmont College



