


Clean Coalition

Local large-scale Battery Energy Storage Systems (BESS)



Craig Lewis
Executive Director
650-796-2353 mobile
craig@clean-coalition.org


Mission

To accelerate the transition to renewable energy and a modern grid through technical, policy, and project development expertise.


Renewable Energy End-Game

100% renewable energy; 25% local, interconnected within the distribution grid and ensuring resilience without dependence on the transmission grid; and 75% remote, fully dependent on the transmission grid for serving loads.

- A microgrid is a combination of energy resources, definitely including generation, that are coordinated to serve specified loads, including in an islanded fashion.
- A Solar Microgrid is a behind-the-meter (BTM) microgrid that solely relies on solar for energy generation when islanded.
- A Hybrid Solar Microgrid is a Solar Microgrid that includes additional sources of energy generation, beyond just solar.
- A Community Microgrid a microgrid that covers a target grid area and relies on existing distribution feeders (ie, power lines) to operate when islanded. Community Microgrids typically include both front-of-meter (FOM) and BTM resources, including Solar Microgrids, and require effective participation from utilities, which have mostly erected barriers to date.



Percentage of time online for Tier 1, 2, and 3 loads for a Solar Microgrid designed for the University of California Santa Barbara (UCSB) with enough solar to achieve net zero and 200 kWh of energy storage per 100 kW solar.




A typical diesel generator is configured to maintain 25% of the normal load for two days. If diesel fuel cannot be resupplied within two days, goodbye. This is hardly a solution for increasingly necessary long-term resilience. In California, Solar Microgrids provide a vastly superior trifecta of economic, environmental, and resilience benefits.

Top owner reserve is often in place to absorb battery energy storage system (BESS) degradation over time, while still delivering the contracted daily cycling energy capacity.

SOCr = the minimum state-of-charge (SOC) that is reserved for provisioning resilience. The SOCr can be dynamic and/or resized to between 0% and 100% of the contracted BESS energy capacity. A lower SOCr facilitates BESS operations that optimize daily economic performance, while a higher SOCr facilitates the provisioning of greater resilience.

Bottom owner reserve is often required to meet BESS warranty requirements that are imposed by BESS vendors.




Contracted BESS energy capacity (kWh) that must be available for daily cycling over the contract duration for achieving specified economic & resilience performance.

A Community Microgrid is a new approach for designing and operating the electric grid, stacked with local renewables and staged for resilience.

Key features:

- A targeted and coordinated distribution grid area served by one or more substations – ultimately including a transmission-distribution substation that sets the stage for Distribution System Operator (DSO) performance.
- Ability to utilize existing distribution grid infrastructure to serve the Community Microgrid during broader grid outages.
- High penetrations of local renewables and other distributed energy resources (DER) such as energy storage and demand response.
- Staged capability for indefinite renewables-driven backup power for critical community facilities across the grid area – achieved by 25% local renewables mix.
- A solution that can be readily extended throughout a utility service territory – and replicated into any utility service territory around the world.






Goleta Load Pocket (GLP)

The GLP is the perfect opportunity for a comprehensive Community Microgrid




- GLP spans 70 miles of California coastline, from Point Conception to Lake Casitas, encompassing the cities of Goleta, Santa Barbara (including Montecito), and Carpinteria.
- GLP is highly transmission-vulnerable and disaster-prone (fire, landslide, earthquake).
- **200 megawatts (MW) of solar and 400 megawatt-hours (MWh) of energy storage will provide 100% protection to GLP against a complete transmission outage (“N-2 event”).**
 - 200 MW of solar is equivalent to about 5 times the amount of solar currently deployed in the GLP and represents about 25% of the energy mix.
 - Multi-GWs of solar siting opportunity exists on commercial-scale built-environments like parking lots, parking structures, and rooftops; and 200 MW represents about 7% of the technical siting potential.
 - Other resources like energy efficiency, demand response, and offshore wind can significantly reduce solar+storage requirements.

Core load area of the GLP



Legend			
	220 kV Transmission		Tier 3 Fire Threat
	Santa Barbara Airport		Tier 2 Fire Threat
	Substations		UCSB
	16kV Gladiola Feeder		Feeder #3556
	16kV Gaucho Feeder		Feeder #4311
	16kV Professor Feeder		Feeder #4157
			Feeder #4169
			Feeder #4227
			Feeder #3565
			Feeder #3559

Target 66kV feeder serves critical GLP loads




Legend			
	66 kV Feeder #4311		University of California Santa Barbara
	Substations		Direct Relief
	Tier 3 Fire Threat		Fire Stations
	16kV Gladiola Feeder		Goleta Sanitary District
	16kV Gaucho Feeder		Dos Pueblos High School
	16kV Professor Feeder		Deckers
	Santa Barbara Airport		Planned Battery Energy Storage
			Goleta Valley Cottage Hospital

Natural gas infrastructure is not resilient

- **Assertion:** Gas-driven generation is often claimed to be resilient.
- **Reality:** Gas infrastructure is not resilient and takes much longer to restore than electricity infrastructure.
- **Threats:** Gas infrastructure can be flat-out dangerous and is highly vulnerable to earthquakes, fires, landslides, and terrorism.




2010 San Bruno Pipeline Explosion




Source: The City and County of San Francisco Lifelines Study


Target 66kV feeder grid area block diagram




VESR can enable resilience to the community



Carpinteria High School, Substation, and ORMAT Battery





(1 of 1)

Substations

Information	
Substation Name	Carpinteria
Substation ID	640
Substation Type	D -- Distribution
System Name	Goleta 220/66 System
Existing Generation (MW)	2.82
Queued Generation (MW)	30.45
Total Generation (MW)	33.27
Projected Load	32.6
Penetration Level	102.56
Maximum Remaining Generation Capacity (MW)	14.55
Note	Interconnection studies in this area have identified adequate deliverability.

The Carpinteria Substation powers multiple feeder circuits across the Eastern Goleta Load Pocket. Currently **2.82MW** of generation is connected to these circuits. Another **14MW** of additional generation can be connected to the Carpinteria Substation.

Carpinteria High School solar potential – 3MW

