



# Solar Microgrids with EV charging optimization

Economic, environmental & resilience benefits

Craig Lewis  
Executive Director  
Clean Coalition  
650-796-2353 mobile  
[craig@clean-coalition.org](mailto:craig@clean-coalition.org)

## Mission

To accelerate the transition to renewable energy and a modern grid through technical, policy, and project development expertise.

### 100% renewable energy end-game


- 25% local, interconnected within the distribution grid and facilitating resilience without dependence on the transmission grid.
- 75% remote, dependent on the transmission grid for serving loads.

- A microgrid is a combination of energy resources, definitely including generation & storage, that are coordinated to serve specified loads, including in an islanded fashion.
- A Solar Microgrid is a behind-the-meter (BTM) microgrid that solely relies on solar for energy generation when islanded.
- A Hybrid Solar Microgrid is a Solar Microgrid that includes additional sources of energy generation, beyond just solar.
- A Community Microgrid a microgrid that covers a target grid area and relies on existing distribution feeders (ie, power lines) to operate when islanded. Community Microgrids typically include both front-of-meter (FOM) and BTM resources, including Solar Microgrids, and require effective participation from utilities, which have mostly erected barriers to date.

# Value-of-resilience (VOR) depends on tier of load


- Everyone understands there is significant value to resilience provided by indefinite renewables-driven backup power, especially for the most critical loads
  - But, this value-of-resilience (VOR) has yet to be quantified in a straightforward methodology.
  - Hence, VOR is often given no value, leaving a dangerously short-sighted economic gap.
- The Clean Coalition aims to establish a standardized [value-of-resilience](#) (VOR) for critical, priority, and discretionary loads that will help everyone understand that premiums are appropriate for indefinite renewables-driven backup power to critical loads and almost constant backup power to priority loads, which yields a configuration that delivers backup power to all loads a lot of the time
- The Clean Coalition's VOR approach standardizes resilience values for three tiers of loads:
  - Tier 1 are mission-critical & life-sustaining loads and warrant 100% resilience. Tier 1 loads usually represent about 10% of the total load with a 3x energy value.
  - Tier 2 are priority loads that should be maintained as long as doing so does not threaten the ability to maintain Tier 1 loads. Tier 2 loads usually represent about 15% of the total load and get a 1.5x energy value.
  - Tier 3 are discretionary loads comprising the remaining loads, usually about 75%. Tier 3 loads possess no extra value and are only maintained when Tier 1 & 2 are secure.






Percentage of time online for Tier 1, 2, and 3 loads for a Solar Microgrid designed for the University of California Santa Barbara (UCSB) with enough solar to achieve net zero and 200 kWh of energy storage per 100 kW solar.

# Diesel generators are designed for limited resilience



A typical diesel generator is configured to maintain 25% of the normal load for two days. If diesel fuel cannot be resupplied within two days, goodbye. This is hardly a solution for increasingly necessary long-term resilience. In California, Solar Microgrids provide a vastly superior trifecta of economic, environmental, and resilience benefits.

# Santa Barbara Unified School District (SBUSD) case study




- The entire Santa Barbara region is surrounded by extreme fire risk (earthquake & landslide risk too) and is extremely vulnerable to electricity grid outages.
- The SBUSD is a major school district that increasingly recognizes the value-of-resilience (VOR) and has embraced the Clean Coalition's vision to implement Solar Microgrids at a number of its key schools and other critical facilities.
- SMHS is in the middle of the extensive SBUSD service area.



Site	Battery Power (kW)	Battery Energy (kWh)	PV Size (kWdc)	Status
Adams ES			98	Final electrical
Cleveland ES			45	Final electrical
District Office & La Cuesta Continuation HS	112	223	110	in construction
Central Food Warehouse & Maintenance Facilities	112	223	76	in construction
Dos Pueblos HS	558	1,115	1,134	Scheduled for June
Franklin ES & Adelante Charter			181	Scheduled for February
Goleta Valley JHS			249	in construction
La Colina JHS			207	Final electrical
La Cumbre JHS & SB Community Academy	223	446	272	Scheduled for March
Monroe ES			106	in construction
Roosevelt ES			121	Scheduled for March
Santa Barbara HS	446	892	620	Scheduled for June
Santa Barbara JHS			219	Final electrical
San Marcos HS	446	892	713	Scheduled for June
	1,896	3,791	4,152	

# Six SBUSD Solar Microgrid sites



Dos Pueblos High School



San Marcos High School



La Cumbre Junior High School




District Food Warehouse  
& District Office




Santa Barbara High School

## Lifetime (28-year) Bill Savings and Added Value of Resiliency





Solar Microgrids deliver unparalleled resilience

# Example NZE total solar generation vs total load



# Islanding full load for an entire year with Hybrid Solar Microgrid




- **31.6%** (716,015kWh requiring 57,076 gallons) of the full load needs to be served by the diesel generator in order to keep the full load online for an entire year.
  - 6,013kWh (481 gallons) served by the diesel generator on the max day (8 Nov 2019)
  - Some level of diesel generation is required every day of the year.


57,281 gallons (~95 fuel tank refills) of diesel needed throughout the entire year

# Islanding T1 load (30% of normal load) for an entire year with Hybrid Solar Microgrid

T1 Load Resource Contributions



T1 Load Resource Stack



- **0.4%** (2,976kWh requiring 212 gallons) of the T1 load needs to be served by the diesel generator in order to keep the T1 load online for an entire year.
  - 615kWh (49 gallons) served by the diesel generator on the max day (9 Nov 2019)
  - Diesel generation is required for 8 days of the year
    - January 2, January 3, April 6, October 13, October 14, November 8, November 9, December 7

212 gallons (35% of existing fuel tank) needed throughout the entire year

EV charging can be critical – and economically viable




- If EV charging is on a dedicated meter, it cannot benefit from the resilience provided by a Solar Microgrid serving the main facility.
- Hence, some or all of the EV Charging Infrastructure (EVCI) should be configured behind-the-meter (BTM).
- EV charging load profiles can be easily developed and added to historical load profiles to perform net zero and economic analyses.

BTM EV charging is also required to optimize economic benefits from coming Policies & Market Mechanisms (P&MM) like those that can be reaped from vehicle-to-building capabilities.


# Typical office charging profile

- Weekday and weekend profiles for an office environment.
- Values show actual data gathered & averaged from a large bank of Level-2 (L2) charging ports capped at 7 kW.
- Note the weekday lunchtime curve as EVs are moved.
- The weekend (orange) curve does not reach the same peak as weekday because the lower utilization reduces the average value.




# Economics could warrant EV charging constraints

- The only natural charging constraint is the power capacity of the L2 EV chargers, which is 7 kW for each port in this example.
- Economic considerations could warrant charging constraints that avoid excessive demand charges and/or minimize energy usage at peak energy rates.
- Additional economic considerations could result from monetizing demand response (DR) and other grid services.



- The purple line shows a maximum EV charging profile that could be set to avoid excessive demand charges and prohibit EV charging via peak energy rates.
- Such limits will be increasingly important as more EV charging proliferates.
- The constrained profile limits charging to 2 kW per port and completely prohibits charging during 4-9pm peak energy rates.




# Valencia Gardens Energy Storage (VGES) case study


# Valencia Gardens Apartments in San Francisco



# Lots of solar on the Valencia Gardens Apartments



# Future VGES Community Microgrid opportunity





Goleta Load Pocket (GLP)  
Community Microgrid  
case study


# Goleta Load Pocket (GLP) and attaining resilience

The GLP is the perfect opportunity for a comprehensive Community Microgrid



- GLP spans 70 miles of California coastline, from Point Conception to Lake Casitas, encompassing the cities of Goleta, Santa Barbara (including Montecito), and Carpinteria.
- GLP is highly transmission-vulnerable and disaster-prone (fire, landslide, earthquake).
- **200 megawatts (MW) of solar and 400 megawatt-hours (MWh) of energy storage** will provide 100% protection to GLP against a complete transmission outage (“N-2 event”).
  - 200 MW of solar is equivalent to about 5 times the amount of solar currently deployed in the GLP and represents about 25% of the energy mix.
  - Multi-GWs of solar siting opportunity exists on commercial-scale built environments like parking lots, parking structures, and rooftops; and 200 MW represents about 7% of the technical siting potential.
  - Other resources like energy efficiency, demand response, and offshore wind can significantly reduce solar+storage requirements.


# Target 66kV feeder at the core of the GLP



**Legend**

220 kV Transmission	16kV Gladiola Feeder	Tier 3 Fire Threat	Santa Barbara Airport
66 kV Feeder #4311	16kV Gaucho Feeder	Tier 2 Fire Threat	Sanitary or Water Districts
Substations	16kV Professor Feeder	University of California Santa Barbara (UCSB)	

# Target 66kV feeder serves critical GLP loads



Legend			
	16kV Gladiola Feeder		Tier 3 Fire Threat
	220 kV Transmission		University of California Santa Barbara
	66 kV Feeder #4311		Fire Stations
	Substations		Sanitary or Water Districts
	16kV Gaucha Feeder		Santa Barbara Airport
	16kV Professor Feeder		Goleta Valley Cottage Hospital
	Substations		Direct Relief
	Santa Barbara Airport		Deckers
	Proposed 160-240 MWh Battery		Proposed 160-240 MWh Battery

# Target 66kV feeder grid area block diagram

