

Clean Coalition

Renewables-driven Microgrids are Key to Future Energy Systems



Craig Lewis

Executive Director

650-796-2353 mobile

craig@clean-coalition.org

Mission

To accelerate the transition to renewable energy and a modern grid through technical, policy, and project development expertise.

Renewable Energy End-Game

100% renewable energy; 25% local, interconnected within the distribution grid and ensuring resilience without dependence on the transmission grid; and 75% remote, fully dependent on the transmission grid for serving loads.

1. Economic

Savings via grid efficiency and lower bills

2. Environmental

Sustainability via renewable energy

3. Resilience

Safety via energy availability

- Solar-only provides solar energy and delivers economic & environmental benefits. The solar will turn off during grid outages and there are no resilience benefits from solar-only.
- Storage-only allows energy to be time-shifted and provides economic and **limited resilience** benefits. Because storage-only simply time-shifts grid energy, solar-only deployments deliver no substantial environmental benefits. The resilience benefits will only last as long as the amount of energy that was stored at the time of a grid outage allows – then it's lights out.
- Solar+Storage combines solar & storage to deliver economic, environmental, and **limited resilience** benefits.
- Solar Microgrid combines to deliver economic, environmental, and **indefinite resilience** benefits. The solar provides an ongoing energy source, which is required for ongoing resilience.


- A microgrid is a combination of energy resources, definitely including generation, that are coordinated to serve specified loads, including in an islanded fashion.
- A Solar Microgrid is a behind-the-meter (BTM) microgrid that solely relies on solar for energy generation when islanded.
- A Hybrid Solar Microgrid is a Solar Microgrid that includes additional sources of energy generation, beyond just solar.
- A Community Microgrid a microgrid that covers a target grid area and relies on existing distribution feeders (ie, power lines) to operate when islanded. Community Microgrids typically include both front-of-meter (FOM) and BTM resources, including Solar Microgrids, and require effective participation from utilities, which have mostly erected barriers to date.

Storage, Resilience, Value-of-Resilience (VOR), and Load Management


Top owner reserve is often in place to absorb battery energy storage system (BESS) degradation over time, while still delivering the contracted daily cycling energy capacity.

SOCr = the minimum state-of-charge (SOC) that is reserved for provisioning resilience. The SOCr can be dynamic and/or resized to between 0% and 100% of the contracted BESS energy capacity. A lower SOCr facilitates BESS operations that optimize daily economic performance, while a higher SOCr facilitates the provisioning of greater resilience.


Bottom owner reserve is often required to meet BESS warranty requirements that are imposed by BESS vendors.



Contracted BESS energy capacity (kWh) that must be available for daily cycling over the contract duration for achieving specified economic & resilience performance.



Percentage of time online for Tier 1, 2, and 3 loads for a Solar Microgrid designed for the University of California Santa Barbara (UCSB) with enough solar to achieve net zero and 200 kWh of energy storage per 100 kW solar.



A typical diesel generator is configured to maintain 25% of the normal load for two days. If diesel fuel cannot be resupplied within two days, goodbye. This is hardly a solution for increasingly necessary long-term resilience. In California, Solar Microgrids provide a vastly superior trifecta of economic, environmental, and resilience benefits.

- Everyone understands there is significant value to resilience provided by indefinite renewables-driven backup power, especially for the most critical loads
 - But, this value-of-resilience (VOR) has yet to be quantified in a straightforward methodology.
 - Hence, VOR is often given no value, leaving a dangerously short-sighted economic gap.
- The Clean Coalition aims to establish a standardized [value-of-resilience](#) (VOR) for critical, priority, and discretionary loads that will help everyone understand that premiums are appropriate for indefinite renewables-driven backup power to critical loads and almost constant backup power to priority loads, which yields a configuration that delivers backup power to all loads a lot of the time
- The Clean Coalition's VOR approach standardizes resilience values for three tiers of loads:
 - Tier 1 are mission-critical & life-sustaining loads and warrant 100% resilience. Tier 1 loads usually represent about 10% of the total load with a 3x energy value.
 - Tier 2 are priority loads that should be maintained as long as doing so does not threaten the ability to maintain Tier 1 loads. Tier 2 loads usually represent about 15% of the total load and get a 1.5x energy value.
 - Tier 3 are discretionary loads comprising the remaining loads, usually about 75%. Tier 3 loads possess no extra value and are only maintained when Tier 1 & 2 are secure.



VOR123

VOR123 is the value-of-resilience (VOR) from Solar Microgrids methodology that the Clean Coalition has developed to normalize VOR across all types of facilities & geographies. The VOR normalization is founded in tiering loads into three categories: Tier 1 (critical), Tier 2 (priority), and Tier 3 (discretionary). Since each Tier has its own resilience requirement and VOR, this methodology is called VOR123.

VOR123 webinar


<https://clean-coalition.org/news/webinar-valuing-resilience-solar-microgrids-thursday-5-nov-2020/>

Load Management is fundamental to VOR123




Although there are multiple potential Load Management configurations, the minimal functionality anticipated to be cost-effectively implemented is referred to as **the Critical Load Panel (CLP) approach**.

The CLP name reflects the requirement for a smart critical load panel that maintains Tier 1 loads indefinitely and toggles Tier 2 loads. In the CLP approach, Tier 3 loads will be toggled as a group by toggling power to the Main Service Board (MSB). Figure 9 illustrates the CLP approach for SMHS, with Tier 1 and Tier 2 loads being served by new dedicated wire runs that connect to a new smart critical load panel.



Getting things done = aligning stakeholders




1. Humans like things to be simple
 - Make sure that objectives & analyses are effectively presented.
2. Most humans are capitalists
 - Economics are fundamental to all stakeholder decisions.
 - With utilities, follow the money.
 - With policymakers, hold them accountable.
3. Success requires multi-pronged action combined with courageous & relentless pursuit
 - Perform comprehensive analyses.
 - Tell the story effectively – which usually means colorfully.
 - Repeat the messaging courageously and ad nauseum.

Think Vertical for maximizing winter solar

Solar sizing and generation per 1,000 sf by orientation type

Example Façade (Not as shown in table)



Fixed Tilt South Facing



Fixed Tilt West Facing




BERMUS Solar Generation by Orientation Type for 1,000 SQFT

Orientation Type	System Size and Annual Generation			Summer and Winter Generation				System Layout Details						
	PV System Size (kWdc)	Annual Generation (kWh)	Annual kWh/kWp	21 June Generation (kWh)	21 June kWh/kWp	21 December Generation (kWh)	21 December (kWh/kWp)	Module Type	Number of Modules	Azimuth (Degrees)	Tilt (Degrees)	Row Spacing (Feet)	Panel Orientation	Field Segment Size in Feet (Length x Width)
Façade South Facing	19.20	21,701	1,130	26.89	1.40	4.47	0.23	Q Cells (400W)	48	180	89	0	Portrait	-
Façade West Facing	19.20	18,221	949	27.09	1.41	4.61	0.24	Q Cells (400W)	48	270	89	0	Portrait	-
Fixed Tilt (Rooftop Canopy) South Facing	14.00	23,323	1,666	34.54	2.47	5.92	0.42	Q Cells (400W)	35	180	23	2.4	Portrait	25 x 40
Fixed Tilt (Rooftop Canopy) West Facing	14.40	20,789	1,444	35.04	2.43	6.17	0.43	Q Cells (400W)	36	270	23	1	Portrait	25 x 40

Daily generation by orientation type




BERMUS Solar Generation by Orientation Type for 1,000 sf



BERMUS - Max and Min Daily Solar Generation by Orientation Type and Date for 1,000 sf					
Time Period		19.2 kW South Facing Façade	19.2 kW West Facing Façade	14 kW South Facing 23 Degree Fixed Tilt Array	14.4 kW West Facing 23 Degree Fixed Tilt Array
Max Daily (kWh)	Annual	106	83	101	99
Max Day		11/8/2022	5/7/2022	6/9/2022	6/9/2022
Min Daily (kWh)		4	4	5	6
Min Day		12/12/2022	12/12/2022	12/12/2022	12/12/2022
Max Daily (kWh)	November - March	105.93	67.41	93.43	73.21
Max Day		11/8/2022	3/24/2022	3/24/2022	3/24/2022
Min Daily (kWh)		4	4	44	6
Min Day		12/12/2022	12/12/2022	12/12/2022	12/12/2022


Monthly generation by orientation type



BERMUS - Total, Max, Average, and Min Daily Solar Generation by Orientation Type and Month for 1,000 sf																
Month	19.2 kW South Facing Façade				19.2 kW West Facing Façade				14 kW South Facing 23 Degree Fixed Tilt Array				14.4 kW West Facing 23 Degree Fixed Tilt Array			
	Total Generation (kWh)	Max Daily Generation (kWh)	Average Daily Generation (kWh)	Min Daily Generation (kWh)	Total Generation (kWh)	Max Daily Generation (kWh)	Average Daily Generation (kWh)	Min Daily Generation (kWh)	Total Generation (kWh)	Max Daily Generation (kWh)	Average Daily Generation (kWh)	Min Daily Generation (kWh)	Total Generation (kWh)	Max Daily Generation (kWh)	Average Daily Generation (kWh)	Min Daily Generation (kWh)
January	1,853	106	60	6	816	39	26	6	1,033	53	33	7	812	39	26	7
February	1,594	104	56	7	816	53	28	7	1,112	70	39	9	904	54	32	9
March	2,261	103	73	16	1,632	67	52	16	2,131	93	68	19	1,747	73	56	19
April	1,920	82	65	25	1,867	81	63	19	2,514	100	85	30	2,185	88	74	25
May	1,603	59	52	34	2,290	83	74	48	2,801	100	90	48	2,693	96	87	56
June	1,325	48	44	27	2,150	81	71	27	2,713	101	90	35	2,704	99	90	35
July	1,464	53	47	33	2,141	78	69	32	2,710	98	87	42	2,688	96	87	43
August	1,738	67	56	16	2,078	78	67	16	2,508	95	81	20	2,341	88	76	21
September	2,006	86	66	14	1,642	67	55	15	2,135	92	71	18	1,789	77	60	19
October	2,194	99	71	10	1,238	54	40	10	1,601	71	52	12	1,323	57	43	12
November	1,934	106	65	8	850	46	29	7	1,117	56	38	9	892	43	30	9
December	1,814	103	59	4	706	36	23	4	948	47	31	5	712	33	23	6
Total	21,706	85	60	17	18,226	64	50	17	23,323	81	64	21	20,790	70	57	22


Solar Microgrids for Schools need support


Solar Microgrid Methodology for feasibility studies





137 kW solar only billing analysis

- 200,000 kWh annual load.
- 50,000 kWh from new anticipated EV chargers.
- 250,000 kWh modeled load.
- 175 kW modeled peak load with EV chargers.
- \$21,000 modeled annual bill (more than 50% demand charges)












Energy Flow for 137 kW solar and 100 kW / 186 kWh storage Solar Microgrid








Solar Microgrids for off-grid facilities


Bull Ridge horizon profile

Project horizon and sunpath



	Energy input kWh/m ² ▾	Energy loss/gain kWh/m ² ▾	Energy PVOUt specific kWh/kWp ▾	Energy loss/gain kWh/kWp ▾	Energy loss %
Global horizontal irradiation (GHI) theoretical	2106.9				
Horizon shading (terrain + horizon objects)	2095.8	-11.1			-0.5
Global horizontal irradiation site specific	2095.8	-11.1			-0.5

The image above depicts the terrain at Bull Ridge Ranch and its impact on the active annual solar area available for solar pv production. The total loss of solar energy production due to surrounding terrain is estimated to be 0.5%



Bull Ridge Solar Microgrid

- Address: 100 Salisbury Canyon Road
- Off-grid

Total annual load and peak demand:

- Baseline load: 8,532 kWh
- Average daily energy use: 23.38 kWh
- Baseline load peak demand: 5.67 kW
- Average load: 0.97 kW

Total solar recommended

- 38.4 kWdc
- 67,901 kWh

Battery energy storage options:


- 20 kW/ 52 kWh

Bull Ridge Solar Microgrid Resilience


Solar size (kWdc)	Solar production (kWh)	Baseline load (kWh)	200% Baseline load (kWh)	300% Baseline load (kWh)	Battery size (kWh)	Percentage of resilience at baseline load	Percentage of resilience at 200% baseline load	Percentage of resilience at 300% baseline load
38.4	67,901	8,532	17,065	25,597	20	99.00%	77.01%	58.26%
					30	99.87%	93.28%	71.10%
					40	99.98%	97.68%	84.13%
					50	100.00%	98.75%	91.21%
					60	100.00%	99.46%	93.52%

Solar Microgrids for grid-constrained load growth

DC-coupled Solar Microgrid to serve 2.5 MWdc of added DC loads to GH2 meter




GH2 economics assuming all future AC & DC loads can be served by the grid



Brand Farms Greenhouse 2 (DC + AC Loads) Business-As-Usual Electricity Bill Cost Based on TOU-8-D and 3CE Rates								
Meter	Scenario Types	Business-As-Usual Blended Utility Rate Over Time at a 5% Utility Price Increase (¢/kWh)			25 Year Electricity Bill Cost			
		Year 1	Year 10	Year 25	Year 1 Total Electricity Bill Cost	Year 10 Electricity Bill Cost	Year 25 Electricity Bill Cost	Total Cumulative 25 Year Electricity Bill Cost
Greenhouse 2 (DC + AC)	No Solar or Storage	\$0.15	\$0.23	\$0.47	\$1,038,158	\$1,610,524	\$3,348,163	\$49,548,269

Energy Flow Diagram 1.5 MW solar and 3 MW / 6 MWh energy storage




Solar Microgrid 25 year cash purchase economics



Brand Farms GH2 (DC+AC) - Solar Microgrid 25 Year Cash Purchase Economic Details

Facility	Annual Electricity Bill Cost (Pre-Solar Microgrid)	Solar Microgrid Cash Purchase - 25 Year Costs and Savings						Value of Resilience
		Capital Expenditure (Capex)	Operational Expenditure (Opex)	Incentives	Net Total Project Cost	Cumulative Utility Bill Savings	Net Cumulative Savings	25 Year Value
GH2 (DC+AC)	\$1,038,158	(\$8,250,000)	(\$5,080,045)	\$5,238,750	(\$8,091,295)	\$10,718,042	\$2,626,747	\$12,387,067

Cash purchase economics use \$2.50/W for solar, \$750/kWh for storage, 5% annual utility escalator, 30% ITC, and Federal & California MACRS




Community Microgrids need
policy innovation

Valencia Gardens Apartments in San Francisco



Future VGES Community Microgrid opportunity




Goleta Load Pocket (GLP)

The GLP is the perfect opportunity for a comprehensive Community Microgrid




- GLP spans 70 miles of California coastline, from Point Conception to Lake Casitas, encompassing the cities of Goleta, Santa Barbara (including Montecito), and Carpinteria.
- GLP is highly transmission-vulnerable and disaster-prone (fire, landslide, earthquake).
- **200 megawatts (MW) of solar and 400 megawatt-hours (MWh) of energy storage will provide 100% protection to GLP against a complete transmission outage (“N-2 event”).**
 - 200 MW of solar is equivalent to about 5 times the amount of solar currently deployed in the GLP and represents about 25% of the energy mix.
 - Multi-GWs of solar siting opportunity exists on commercial-scale built-environments like parking lots, parking structures, and rooftops; and 200 MW represents about 7% of the technical siting potential.
 - Other resources like energy efficiency, demand response, and offshore wind can significantly reduce solar+storage requirements.

Core load area of the GLP




Legend			
	220 kV Transmission		Tier 3 Fire Threat
	Santa Barbara Airport		Tier 2 Fire Threat
	Substations		UCSB
	16kV Gladiola Feeder		Feeder #3556
	16kV Gaucho Feeder		Feeder #4311
	16kV Professor Feeder		Feeder #3559
	Feeder #4157		Feeder #4169
	Feeder #4227		

Target 66kV feeder serves critical GLP loads



Legend			
	66 kV Feeder #4311		University of California Santa Barbara
	Substations		Direct Relief
	Tier 3 Fire Threat		Fire Stations
	16kV Gladiola Feeder		Goleta Sanitary District
	16kV Gaucho Feeder		Goleta Valley Cottage Hospital
	16kV Professor Feeder		Planned Battery Energy Storage
	Santa Barbara Airport		Direct Relief
			Deckers

Target 66kV feeder grid area block diagram



Backup slides

Load Profiles

Baseline Load Profile

- Using LifeMoves Mountain View as proxy, the baseline load profile is calculated based on the ratio between the LifeMoves Mountain View total annual load and the forecasted DignityMoves Santa Maria total annual load as provided by DignityMoves.
 - LifeMoves Mountain View’s total 2021 actual annual load was 207,122 kWh
 - DignityMoves Santa Maria’s forecasted total annual load (per DignityMoves) is 333.97 estimated daily kWh, equaling 121,899 kWh annually.
- Thus, DignityMoves Santa Maria is expected to be roughly 58% of LifeMoves Mountain View’s total annual load.
- 58% of every 15-minute interval for LifeMoves Mountain View was taken to form DignityMoves Santa Maria’s baseline load profile.

DM Santa Maria - Current Rate and Billing Analysis Based on Baseline Load Profile							
PG&E and 3CE's Rate Schedule	Annual Load from Baseline Load Profile (kWh)	Peak Demand (kW)	Effective Blended Rate ¢/kWh	Total Annual Bill	Energy Charges	Demand Charges	Fixed Charges
B1	121,899	41	28.9	\$35,215	\$31,739	\$0	\$3,476

DignityMoves SM – critical load profile

Key Points:

- LifeMoves Mountain View Critical Load Profile was used as the basis for Santa Maria and would include the following critical loads: food and community services, bathrooms, restrooms, security lighting, exterior lights, office lights, reception lights, parking lot lights.
- See actual critical load breakdown for Mountain View in next slide, as example for Santa Maria.
- **HOWEVER: Note that for the on-grid scenario with 2 BESS containers, the total percentage of loads kept on indefinitely is 35%, much higher than 11.4%.**

Tier:	All tiers	<u>1</u>	<u>2</u>	<u>3</u>
Watts (VA):	570,273	65,243	26,352	444,499
Tiering by Watts %:	100.0%	11.4%	9.5%	77.9%

Clean Coalition's VOR 123 Methodology	At the Clean Coalition, we've developed a standardized Value of Resilience (VOR) metric. Our VOR123 methodology makes it simple to quantify VOR by standardizing VOR for three tiers of loads — critical, priority, and discretionary loads — across all facility types:
Tier 1:	Mission-critical, life-sustaining loads that warrant 100% resilience — usually about 10% of a facility's total load.
Tier 2:	Priority loads that should be maintained as long as doing so does not threaten the ability to maintain Tier 1 loads — usually about 15% of the total load.
Tier 3:	Discretionary loads that should be maintained only when doing so does not threaten Tier 1 and Tier 2 resilience — usually about 75% of the total load.

Example for Santa Maria – LifeMoves MV Critical load profile and tiering




Electrical Panels and Loads				Watts (VA)	Percentage of Total Load	Percentage of T1 Load	Tier 1	Tier 2	Tier 3
MSB	CDP1	Food SVC Module FS-1 Food SVC Module FS-2 Food SVC Module FS-3 Module Laundry Storage - North Community Bldg PNL Module 24/TS-1L - Bathrooms Module 24/TS-1R - Bathrooms Module Restroom	Refrigerator	29,952	5.25%		X		
			Microwave (Prep - CTR RH)	27,248	4.78%		X		
			Microwave (Prep - CTR LH)						
			Conven Outlet (Prep - LH)						
			General LTS & Vent Fan						
			Conven Outlet (Flex - Rear wall)						
			Campus Lighting (exerior)						
			Conven Outlet (exterior)	12,272	2.15%	18.8%	X		
			Microwave (Prep - LH)						
			Air Conditioning (x2)						
			Conven Outlet (IT RM - LH wall)						
			Conven Outlet (IT RM - Entry & RH)						
		Conven Outlet (IT RM - Server LWR)							
		Conven Outlet (IT RM - Server UPR)							
		Conven Outlet (IT RM - Rear Wall)							
		Microwave (Prep Area - RH)							
			24,274	4.26%				X	
			2,080	0.36%				X	
			7,904	1.39%	12.1%	X			
			6,448	1.13%	9.9%	X			
			6,448	1.13%					
			5,616	0.98%	8.6%	X			
		Falcon PNL A	Intake/Security Lights	84	0.01%	0.1%	x		
			Exterior Lights	138	0.02%	0.2%	x		
			Intake Reception Room	360	0.06%	0.6%	x		
Security Rec	360		0.06%	0.6%	X				
Packaged Terminal Air Conditioner (PTAC)	2,304		0.40%			x			
Falcon PNL B (North Support Services)	Offices/Staff Break Lights		147	0.03%		x		x	
	Exterior Lights (3 brkrs)		345	0.06%	0.5%				
	Flex (multipurpose) Office Reception (3 brkrs)		2,160	0.38%				x	
	Staff Break Reception		540	0.09%			x		
	Nurse Medical Reception		720	0.13%			x		
	Packaged Terminal Air Conditioner (PTAC)		9,216	1.62%				x	
	Offices Lights		84	0.01%			x		
	Offices/Nurse/Medical Lights	147	0.03%	0.2%	x				
	IWH - 1 (2 units)	12,480	2.19%			X			
	Medical Fridge	1,200	0.21%	1.8%	x				
	Refrigerator	1,200	0.21%			X			
	Disposal	1,200	0.21%				x		
Coffee Maker	1,200	0.21%				x			
Microwave	1,200	0.21%				x			
Falcon PNL C (South Support Services)	Offices/Meeting Lights	147	0.03%				x		
	Exterior Lights	483	0.08%	0.7%					
	Flex (multipurpose) Office Reception	2,160	0.38%				x		
	Meeting Reception Room	1,440	0.25%				x		
	Lounge Reception (Family room for managing families)	1,080	0.19%			x			
	Microwave	1,200	0.21%				x		
	Coffee Maker	1,200	0.21%				x		
	IWH-1	6,240	1.09%			X			
	Disposal	864	0.15%				x		
	Office Lights	84	0.01%				x		
	Lounge /Offices/Meeting Lights	273	0.05%				x		
	Packaged Terminal Air Conditioner (PTAC)	11,520	2.02%				x		
RDP1	Module Panel - Single Family Unit 1, 7	35,360	6.20%				X		
	Module Panel - Two Family Unit 2, 3, 4, 5, 6	95,470	16.74%				X		
	Electrical Vehicle Charging Station - 1, 2	13,312	2.33%				X		
	Reception - Main Service Area	180	0.03%	0.3%	X				
	Storage South	8,320	1.46%				X		
	Parking Lot Lights	237	0.04%	0.4%	X				
DP2	4 Bed Unit 1,2,3,4,5,6,7,8,9,10,11	116,688	20.46%				X		
DP3	4 Bed Unit 12,13,14,15,16,17,18,19,20,21,22	116,688	20.46%				X		

Legend
X: Clean Coalition choice based on new loads discovered during site walk
x: LifeMoves original choice

DignityMoves SM – Battery sizing (2 BESS) with solar on Boss Cubez units



DignityMoves Santa Maria - On-Grid HomeGrid Battery Energy Storage Sizing, System Cost, and Resilience							
Baseline Load Profile Peak Demand (kW)	Solar System Size (kW)	Recommended Battery System Size		Battery System Cost		Indefinite Resilience	
		Standard Option Battery Power Capacity (kW)	Standard Option Battery Energy Capacity (kWh)	Total Battery Energy Storage System Cost	Battery Energy Storage System Cost per kWh	Total Percentage of Load Kept Online Indefinitely (Year 1)	Total Percentage of Load Kept Online Indefinitely (Year 15 - before replacement)
41	86.4	150	307	\$269,717	\$878	40.0%	35.0%



The total annual energy gap is 22,159 kWh. When on-grid, this energy gap is supplied by the grid. When off-grid, this energy gap would require 1,773 gallons of diesel fuel for 1 year – see diesel generator details in next slide.

For mid-March through October, solar and storage should be enough to cover 100% of the site’s electrical load, except for the following three days:

- Date – 22 March (67 kWh)
- Date – 7 September (20 kWh)
- Date – 14 October (8 kWh)